



ATTAR

Advanced Technology Testing and Research

- *Acoustic Emission * Slip Resistance Testing
- *Materials Failure Analysis *Corrosion Monitoring
- *Non-Destructive Testing Training

A Division of Engineering Materials Evaluation Pty. Ltd.
A.B.N. 14 006 554 785

ATTAR TEST REPORT NUMBER: 06/0826.2



This document is issued in accordance with NATA's accreditation requirements. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards. Accredited for compliance with ISO/IEC 17025.

June 7, 2006

Total Pages: 1

WET SLIP RESISTANCE

Job No: M06/0826

Prepared for:	Arrk Australia & New Zealand Pty Ltd. 5 Lynch Street HAWTHORN VIC 3122					
Attention:	Tim Lawson					
Test Site:	ATTAR, Unit 27, 134 Springvale Road, Springvale.					
Test Date:	May 30, 2006					
Test Specimens, Size & Quantity:	Thruflow walkway panels, 122cm x 29.5cm, 2 off.					
Sampling & Direction of Testing:	Sampling conducted by client. Tested in the longitudinal direction.					
Test Personnel:	John Dimopoulos					
Preparation:	As received, washed in tap water and methylated spirits and dried.					
Fixed/Unfixed:	Unfixed.					
Air Temperature:	21°C					
Test Equipment:	Stanley Skid Resistance Tester (Pendulum) Serial Number 8117, Calibrated 11/04/2006.					
Test Standard:	AS/NZS 4586 - 2004 Slip resistance classification of new pedestrian surface materials – Appendix A.					
Slider Rubber:	Slider 55 (TRL) Batch No. 14					
Classification Criteria:	Refer Appendix 3 – Classification Criteria, attached.					
British Pendulum Number	Specimen Number					Mean
	1	2	3	4	5	
	80	80	79	79	81	80
Classification:	V					

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance procedures and wear on their slip-resistance be checked.

NOTE: Any specimens supplied will be disposed of in two (2) months time, unless otherwise instructed.

ATTAR

David Padfield
Materials Engineer

This report may not be reproduced except in its entirety.

27/134 Springvale Road, PO Box 286, SPRINGVALE VIC. 3171
Phone: (03) 9574 6144 Fax: (03) 9574 6133
www.attar.com.au Email: admin@attar.com.au